



SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor
Dave Ross, Secretary

February 27, 2012

CONTINUUM FOOTSPAS, LLC
JOE GALATI
2236 S. 162 STREET
NEW BERLIN WI 53151

Re: Description: WHIRLPOOL FOOT SPA
Manufacturer: CONTINUUM FOOTSPAS, LLC
Product Name: PEDICURE CHAIRS
Model Number(s): ECHO/VANTAGE AND THE MAESTRO
Product File No: 20120064

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 384.20 based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of February 2017.

This alternate approval is contingent upon compliance with the following stipulation(s):

- The faucets on this product shall conform to ASME A112.18.1 standard.
- The cross connection control (CCC) method shall not be in conflict with the requirements and limitations of the standard that the CCC method conforms to.
- When using a pump discharge, the discharge pipe shall terminate with an approved receptor, with an air break or air gap.
- When there is a gravity discharge this product shall be direct connected to the drain system..

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: jerry.thompson@wi.gov