



May 14, 2012

VIEGA LLC
ANDREW GRANZOW
301 N MAIN ST STE 900
WICHITA KS 67202

Re: Description: FITTINGS, COPPER
Manufacturer: VIEGA LLC
Product Name: PROPRESS SYSTEM
Model Number(s): ADAPTER C X M: 1/2" X 3/8" NPT THRU 4" X 4" NPT; ADAPTER C X F: 1/2" X 3/8" NPT THRU 2" X 2"; ADAPTER FTG X M: 1/2" X 3/8" NPT THRU 2" X 2"; ADAPTER FTG X F: 1/2" X 3/8" NPT THRU 2" X 2" NPT; CAP C: 1/2" THRU 4"; COUPLING C X C WITH STOP: 1/2" THRU 4"; COUPLING C X C WITH NO STOP: 1/2" THRU 4"; CROSS-OVER C X C: 1/2", 1"; CROSS-OVER FTG X C: 1/2", 1"; ELBOW 90 DEGREE C X C CLOSE ROUGH: 1/2" THRU 4"; ELBOW 90 DEGREE FTG X C CLOSE ROUGH: 1/2" THRU 4"; ELBOW 45 DEGREE C X C: 1/2" THRU 4"; ELBOW 45 DEGREE FTG X C: 1/2" THRU 4"; ELBOW 90 DEGREE C X M: 1/2" X 1/2" NPT THRU 2" X 2" NPT; ELBOW 90 DEGREE C X F: 1/2" X 1/2" NPT THRU 2" X 2" NPT; ELBOW 90 DEGREE FTG X F: 1/2" X 1/2" NPT; ELBOW DROP 90 DEGREE FTG X F: 1/2" X 1/2" NPT, 1" X 1" NPT; REDUCER C X C: 1" X 1/2" THRU 2" X 1-1/2"; REDUCER FTG X C: 1" X 1/2" THRU 4" X 3"; TEE C X C X C: 1/2" X 1/2" X 1/2" THRU 4" X 4" X 3"; TEE C X C X F: 1/2" X 1/2" X 1/2" NPT THRU 4" X 4" X 2" NPT; UNION C X C: 1/2" THRU 2"; UNION C X F: 1/2" X 1/2" NPT THRU 2" X 2" NPT; UNION C X M: 1/2" X 1/2" NPT THRU 2" X 2" NPT; PRESSURE TEST PLUG: 1/2" THRU 2"; AND ADAPTER FLANGE C X FLANGE: 1" THRU 4"

Product File No: 20120176

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 384.40 (8) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of July 2017.

This alternate approval is contingent upon compliance with the following stipulation(s):

- Approval is issued for this product because the design of the product meets the intent of s. SPS 384.40 (8), Wis. Adm. Code that requires mechanical compression type joints for water supply which use flexible elastomeric seals to be suitable for potable water. The intent of the code is met since this product provides an acceptable elastomeric seal.

VIEGA LLC
Page 2
May 14, 2012
20120176

This approval supersedes the approval issued on July 24, 2007 under product file number 20070357.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20070357.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: jerry.thompson@wi.gov