



SAFETY AND BUILDINGS DIVISION  
Plumbing Product Review  
P.O. Box 2658  
Madison, Wisconsin 53701-2658  
TTY: Contact Through Relay

Scott Walker, Governor  
Dave Ross, Secretary

June 15, 2012

**Reissued: November 8, 2016**

DONE RIGHT CONCRETE LLC  
MYRON KNETTER  
5065 ALPINE RD  
EDGAR WI 54426

Re: Description: SEWAGE TANKS, SITE CONSTRUCTED (voluntary)  
Manufacturer: DONE RIGHT CONCRETE LLC  
**Product Name: HOLDING**  
**Model Number(s): 10,000 GALS.**  
**[78 IN. L.L., actual capacity 10,696 gals.; MAX. DEPTH OF BURY 15 FT.;**  
**TANK DIMENSIONS (ID) = 22 FT. L X 10 FT. W X 6.5 FT. H]**  
**Product File No: 20120220**

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 384.10 (2) based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of June 2017.**

This alternate approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- Construction of this product must be designed and constructed in conformance with the specifications submitted and approved by this department and the sealant manufacturer's printed directions for use for the sealant materials.
- The manufacturer must keep a set of plans and specifications for this product bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- **Bedding: Tanks must be placed on soils capable of bearing the weight of tank and its contents, when full. Soft soils or bedrock must have 3 inches of tamped material, sand or gravel, 100% of which passes ½ -inch screen.**
- **BACKFILL: Fill must contain no stones or debris larger than 3 inches in diameter. Place backfill in uniform layers no larger than 24 inches.**
- This product is approved to use the following:
  - Pipe materials constructed in conformance with Table SPS 384.30-2 or 384.30-11, Wis. Admin. Code poured into tank . Variable height risers by County Materials.
  - Two inch schedule 40 PVC cast in riser for electrical wiring.
  - Four inch inlet opening.
  - Sinmast coatings.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST--Engineering Consultant--Plumbing Products Review  
DPS WEST, Safety & Buildings Div., PO Box 2658, 201 W Washington Ave., Madison WI 53703-2658  
Phone: 608-266-0955; Fax: 608-283-7456, E-mail: Jean.MacCubbin@WI.GOV