



SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor
Dave Ross, Secretary

June 28, 2012

APPLIED MECHANICAL
JUSTIN LIGOCKI
1638 S. WEST AVE SUITE A
WAUKESHA WI 53189

STARBUCKS COFFEE COMPANY
ROB DARLIN
550 WEST WASHINGTON BLVD #200
CHICAGO IL 60661

Re: Description: ALTERNATE PRODUCT REVIEW FEE
Manufacturer: STARBUCKS COFFEE COMPANY
Product Name: VITA MIX RINSE-O-MATIC
Model Number(s): VM0134
Product File No: 20120244

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 382.41(3) (a) & 384.30 (4) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of June 2017.

This alternate approval is contingent upon compliance with the following stipulation(s):

- The spray holes shall be installed at least 1" above the flood level of the sink that it is placed in.
- With the Quick connect fitting installed on the faucet, a hose connection vacuum breaker is not required.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: jerry.thompson@wi.gov