



SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor
Dave Ross, Secretary

July 3, 2012

BUFFALO DENTAL MFG
RICHARD BYALICK
159 LAFAYETTE DR
SYOSSET NY 11791-0678

Re: Description: TRAP
Manufacturer: BUFFALO DENTAL MFG
Product Name: TRAP-EZE
Model Number(s): 62100, 62110 & 62112
Product File No: 20120247

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 384.30 (2) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of August 2017.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product may only be installed in accessible areas.

This approval supersedes the approval issued on May 24, 2007 under product file number 20070251

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20070251

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: jerry.thompson@wi.gov