



August 16, 2012

JSH INTERNATIONAL
GREENOVATIVE TECHNOLOGIES
DANIEL WEINTRAUB
303 BIRCHFIELD DRIVE
MOUNT LAUREL NJ 08054

Re: Description: SEPTIC TANK ADDITIVE - CHEMICAL OR BIOCHEMICAL
Manufacturer: JSH INTERNATIONAL
Product Name: ECOHANCER
Model Number(s): ECO-016 AND ECO-064
Product File No: 20120280

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of August 2017.

This approval is contingent upon compliance with the following stipulation(s):

- If the formulation of this approved septic tank additive is modified, or additional assertions of function or performance are made, then this approval shall be rendered null and void, unless the change is submitted to this department for review and the approval reaffirmed.
- This product does not replace the need for a regular program of inspection and maintenance. This includes having the tank pumped out when the volume of sludge and/or scum occupies one-third of the tanks liquid capacity.
- Based on information supplied by the manufacturer and reviewed by this department, the approval for this product recognizes this septic tank additive will not adversely affect the user, the bacterial action in septic systems, the soil hydraulic conductivity in soil absorption areas, or groundwater quality, when used in accordance with the manufacturer's instructions.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Engineering Consultant
Safety and Buildings Division
Department of Safety and Professional Services
(608) 267-1401 Phone
(608) 267-9566 Fax
glen.schlueter@wi.gov Email
7:30AM - 4:30PM CT Work Hours
GWS:gws