



SAFETY AND BUILDINGS DIVISION  
Plumbing Product Review  
P.O. Box 2658  
Madison, Wisconsin 53701-2658  
**TTY: Contact Through Relay**

**Scott Walker, Governor**  
**Dave Ross, Secretary**

August 8, 2012

DEMA ENGINEERING CO.  
ENGINEERING  
SONE CHAN  
10020 BIG BEND BLVD.  
ST. LOUIS MO 63122

Re: Description: PROPORTIONER  
Manufacturer: DEMMA ENGINEERING CO.  
Product Name: FAUCET ADAPTER  
Model Number(s): 68-4-2, 68-4-2A, 68-4-3, 68-4-3A, 68-4-4, 68-4-4 AND 68-21  
Product File No: 20120288

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 384.11 based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of December 2017.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product may be installed in conjunction with faucets manufactured by Chicago, Fisher, and T&S to allow for connection to DEMMA Blend Center units with a 163AG and/or 164AG air-gap proportioners that comply with ch. SPS 382 and 384 of the Wis. Adm. Code.
- The NSF 51 hose that is used to connect the proportioner to this product must have a pressure rating equal to or greater than 100 psig @ 180 degree F.

This approval supersedes the approval issued on December 20, 2007 under product file number 20070546.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20070546.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson  
Plumbing Product Reviewer  
Phone: 608-266-6742  
Fax: 608-267-9566  
E-mail: jerry.thompson@wi.gov