



August 20, 2012

BLUE WHITE INDUSTRIES  
BILL MCDOWELL  
5300 BUSINESS DR.  
HUNTINGTON BEACH CA 92649

Re: Description: WATER TREATMENT CHEMICAL INJECTION DEVICE - POE  
Manufacturer: BLUE WHITE INDUSTRIES  
Product Name: A-100N FLEXFLO SERIES PERISTALTIC METERING PUMPS  
Model Number(s): A-100NC, A-100NE, A-100NF and A-100NV  
(The complete model numbers will include additional digits and/or letters that pertain to strokes per minute, input voltage and power supply, electronic controls, pump tube type/size, "on" timer units, "on" cycle units, "total" time units, options and tubing connection size. See the manufacturer's "A-100N PRODUCT SELECTION GUIDE-2007."  
Product File No: 20120300

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of August 2017.

This approval supersedes the approval issued on January 16, 2008 under product file number 20070548.

This approval is contingent upon compliance with the following stipulation(s):

- Water treatment compounds introduced into the water supply system by these devices shall be listed as an acceptable drinking water additive by a listing agency approved by this department. Listing agencies approved by this department shall include:
  - a. United States Environmental Protection Agency;
  - b. United States Food and Drug Administration; and
  - c. NSF International
- A water supply system shall be protected from backflow when unlisted water treatment compounds, which may affect the potability of the water, are introduced into the system. This department shall determine the method of backflow protection. Water supply outlets for human use or consumption may not be installed downstream of the introduction of an unlisted water treatment compound.
- This product has undergone sufficient testing to document the product's ability to properly inject a chemical into a water supply system as specified in this approval letter.
- For buildings not served by a municipal water supply, Department of Natural Resources (DNR) written approval may be required prior to installation of this product to inject a chemical into a water supply system. For more information contact the DNR Private Water Systems Section, P.O. Box 7921, Madison, WI 53707, telephone (608) 267-9787.

Blue White Industries  
August 20, 2012  
Page 2 of 2  
Product File No.: 20120300

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter  
Engineering Consultant  
Safety and Buildings Division  
Department of Safety and Professional Services  
(608) 267-1401 Phone  
(608) 267-9566 Fax  
glen.schlueter@wi.gov Email  
7:30AM - 4:30PM CT Work Hours

GWS:gws