



August 18, 2015

DEPT. OF SAFETY AND PROFESSIONAL SERV.
1400 E. WASHINGTON AVE
MADISON WI 53703

Re: Description: ALTERNATE STANDARD
Manufacturer: DEPT. OF SAFETY AND PROFESSIONAL SERV.
Product Name: ASME A112.18.3-2002
Model Number(s): PERFORMANCE REQUIREMENTS FOR BACKFLOW PROTECTION DEVICES AND SYSTEMS IN PLUMBING FIXTURE FITTINGS
Product File No: 20120315

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of August 2017.

This approval is contingent upon compliance with all of the following stipulation(s):

This device is approved for only pull out hose-spray faucets or supplies from water treated for high purity use is involved.

1. The dual check valve may be installed for high and low hazard situations;
2. The dual check valve may be installed within the fixture supply or the hose-spray;
3. The flow through the dual check valve has a maximum flow rate of 2.0 gpm;
4. The dual check valve is accessible for maintenance and testing per manufactures instructions;
5. The dual check valve must be tested before installation and once annually thereafter;
6. The maximum water inlet supply of the fixture, appliance or device to be connected is 3/8" nominal pipe size supply.
7. A hose holder shall be incorporated to prevent the hose outlet from being submerged when not in use.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Thomas Braun – Supervisor
Department of Safety and Professional Services
Division of Industry services
Bureau of Technical Services
Phone: 715-634-5124
Email: thomas.braun.wisconsin.gov