



November 9, 2012

CORRIGAN CORPORATION OF AMERICA
MICHAEL CORRIGAN
104 AMBROGIO DRIVE
GURNEE IL 60031

Re: Description: MISTING SYSTEM
Manufacturer: CORRIGAN CORPORATION OF AMERICA
Product Name: ULTRAMIST OVERHEAD MISTING SYSTEM
Model Number(s): UxxxW, UxxxB and WxxxU (xxx = feet of piping)
Product File No: 20120338

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of November 2017.

This approval supersedes the approval issued on September 12, 2007 under product file number 20070374.

This approval is contingent upon compliance with the following stipulation(s):

- The use of this system must conform to all applicable United States Food and Drug Administration (USFDA), Wisconsin Department of Agriculture, Trade and Consumer Protection (DATCP) and other governing regulatory agency requirements.
- The black PVC tubing may be installed for the following water use:
 - a. Overhead inter-misting head water distribution piping. . . . aboveground cold only
- The black PVC tubing used in this system must be labeled with the Corrigan Company logo, nominal tubing size, pressure rating and the statement "for cold water supplies only." Also, the tubing must conform to NSF Standard 51 for aqueous food or NSF Standard 61 for potable water contact.
- This product must be installed and joints made in accordance with the manufacturer's published instructions.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 266-2602 Fax
glen.schlueter@wi.gov E-mail