



April 12, 2013

BRAUN CONCRETE & EXCAVATING, INC.
TOM REIGEL
609 W SOUTH ST
LOYAL WI 54446

Re: Description: SEWAGE TANKS, SITE CONSTRUCTED (voluntary)
Manufacturer: BRAUN CONCRETE & EXCAVATING, INC.
Product Name: HOLDING TANK
Model Number(s): 5000-6
(66 IN. L.L., 74.8 GAL./IN., 36 IN. MAX. BURY DEPTH, 4937 TOTAL GALLONS; TANK
DIMENSIONS (ID) = 188 IN. L X 96 IN. W X 72 IN. H)
Product File No: 20130031

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of April 2018.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.

This approval supersedes the approval issued on 5/7/2008 under product file number 2008243.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 2008243.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen A. Jones
Public Swimming Pool Plan / Plumbing Product Reviewer
phone: (608) 267-5265
fax: (608) 266-2602
email: glen.jones@wi.gov