



April 26, 2013

DALMARAY CONCRETE PRODUCTS, INC
AARON AUSEN
405 S ARCH ST
JANESVILLE WI 53548

Re: Description: SEWAGE TANKS, CONCRETE
Manufacturer: DALMARAY CONCRETE PRODUCTS, INC
Product Name: SEPTIC, HOLDING, PUMP OR SIPHON
Model Number(s): 1400
(42.5 IN. L.L., 33 GAL/IN., 108 IN. MAX. DEPTH OF BURY, 671 G.P.D. WHEN USED AS A SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL WASTEWATER; TANK DIMENSIONS (OD) = 118 IN. L X 78 IN. W X 60 IN. H)

Product File No: 20130033

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of April 2018.**

This approval is contingent upon compliance with the following stipulation(s):

- This product is approved to use the following:
 - Four-inch opening located in interior wall and between a distance of 9-inches below liquid level and above 1/3 of liquid level above bottom of tank for septic tanks only.
 - Four or eight-inch opening in tank or access cover.
 - Six-inch inlet and outlet openings.
 - Bottom and side pipe openings for siphon, pump and holding tanks.
 - Dual 4" four inch inlets and/or outlets.
 - Four-inch discharge opening in riser.
 - Three-inch schedule 40 PVC cast in riser for electrical wiring.
 - Cast-A-Seal and PSX Gasket System by Press Seal Gasket Corp., Polylok II High Pressure Pipe Seal by Polylok, and A-Lok X-Cel by A-Lok Products, Inc.
 - Pipe materials constructed in conformance with Table SPS 384.30-2 or 384.30-11, Wis. Admin. Code poured into tank cover, access cover or interior wall.
 - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.

April 26, 2013

- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 greater than 30 mg/L but less than or equal to 220 mg/L, TSS greater than 30 mg/L but less than or equal to 150 mg/L and F.O.G. less than or equal to 30 mg/L.
- Tank Bedding: •Bedding should be compacted granular fill that has the ability to pass 100% through as ¾ inch sieve. Bedding should be compacted to a 4 inch minimum depth. In the case of soils with poor bearing capacity, bed design may change to resist floating. Engineering specification may warrant change in bedding specifications.
- Additional information is included as attachment(s) to this letter; see attachment A.

As of May 15, 2008, a copy of a successful water tightness test report for this product must be AVAILABLE FOR INSPECTION AT THE MANUFACTURER'S PLANT prior to this product being used as a POWTS holding or treatment tank in Wisconsin.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen A. Jones
Public Swimming Pool Plan / Plumbing Product Reviewer
phone: (608) 267-5265
fax: (608) 266-2602
email: glen.jones@wi.gov