



DIVISION OF INDUSTRY SERVICES
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor
Dave Ross, Secretary

June 13, 2013

WEXCO COMPANIES INC.
WEXCO ENVIRONMENTAL
ERIC LARSEN
6074 KEYSTONE RD.
MILACA MN 56353

SCHAUS-VORHIES COMPANIES
SCHAUS-VORHHIES WATER TREATMENT LLC
ROGER VORHIES
609 W. GRIMES
FAIRFIELD IA 52556

Re: Description: CHEMICAL OR PHYSICAL RESTORATION FOR POWTS
Manufacturer: SCHAUS-VORHIES COMPANIES
Product Name: MICRO BUBBLE DIFFUSION (MBD) AERATION TECHNOLOGY
Model Number(s): MBD-3, MBD-6, MBD-8 AND MBD-12
Product File No: 20130034

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of June 2018.**

This approval is contingent upon compliance with the following stipulation(s):

- This product must be utilized in accordance with the manufacturer's printed installation instructions and this product approval. If there is a conflict between the manufacturer's installation instructions and the product approval, the product approval requirements will take precedence.
- The elevation of the system's infiltrative surface must be above the estimated highest groundwater elevation or bedrock by the distance prescribed in column entitled "Fecal Coliform >10000 cfu/100 ml" in Table SPS 383.44-3, Wis. Adm. Code.
- A copy of this approval letter and the manufacturer's printed installation instructions must be supplied to the buyer of this product.
- The outlet baffle of the septic tank, which has this product installed, must have installed an effluent filter capable of filtering particles of 1/8 inch in size or larger.
- This product must be installed by a properly licensed plumber.
- A state Sanitary Permit must be obtained when this product is installed.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen A. Jones
Public Swimming Pool Plan / Plumbing Product Reviewer
phone: (608) 267-5265
fax: (608) 266-2602
email: glen.jones@wi.gov