



Scott Walker, Governor  
Dave Ross, Secretary

April 11, 2013

NORWESCO, INC.  
ANASTASIA R. O'HARA  
PO BOX 439  
ST BONIFACIUS MN 55375-0439

Re: Description: SEWAGE TANKS, POLYETHYLENE  
Manufacturer: NORWESCO, INC.  
Product Name: PUMP  
Model Number(s): 500 GAL. SPHERE (PART NO. 40785)  
[46.5 IN. L.L., 30 IN. MAX. DEPTH OF BURY, SEE STIPULATIONS FOR GALLONS PER INCH]  
Product File No: 20130035

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of April 2018.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- A permanent warning label that conforms to s. SPS 384.25 (8), Wis. Adm. Code, must be attached to the cover of this product.
- The gallon capacity per inch of the NORWESCO 500 gallon dose tank is shown in the table below.

Height from pump base	Gallons capacity	Height from pump base	Gallons capacity	Height from pump base	Gallons capacity
1	13	17	185	33	410
2	20	18	199	34	422
3	28	19	213	35	434
4	36	20	227	36	445
5	45	21	242	37	456
6	54	22	256	38	466
7	64	23	271	39	476
8	74	24	295	40	485
9	85	25	308	41	594
10	96	26	321	42	503
11	108	27	335	43	511
12	120	28	348	44	518
13	133	29	361	45	525
14	145	30	373	46	531
15	158	31	386	47	537
16	172	32	398		

NORWESCO, INC.

Page 2

April 11, 2013

This approval supersedes the approval issued on 6/3/2008 under product file number 20080280.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20080280.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones

Public Swimming Pool Plan / Plumbing Product Reviewer

phone: (608) 267-5265

fax: (608) 266-2602

email: [glen.jones@wi.gov](mailto:glen.jones@wi.gov)