



SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor
Dave Ross, Secretary

February 22, 2013

SAIC
JOHN A RIEKE
60 EAST PLATO BLVD., STE 300
SAINT PAUL MN 55107

WALMART STORES
PAULA WAGNER
2001 SE 10TH STREET
BENTONVILLE AR 72716

Re: Description: ALTERNATE SYSTEM
Manufacturer: WALMART STORES
Product Name: CASE MAINTENANCE HOSE BIBB HB-4
Model Number(s): NONE
Product File No: 20130046

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 382.40 (5) (b) 1. based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of February 2018.

This alternate approval is contingent upon compliance with the following stipulation(s):

- Temperature maintenance will not be required in accordance with the above referenced subdivision based on customers use, and food display case cleaning procedures.
- The exemption only applies to case maintenance hose bibbs.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Timothy J. Lamb
Plumbing Plan Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
Madison WI 53703-2658
608-266-9647 Phone
608-266-2602 Fax
tim.lamb@wi.gov E-mail