



SAFETY AND BUILDINGS DIVISION  
Plumbing Product Review  
P.O. Box 2658  
Madison, Wisconsin 53701-2658  
**TTY: Contact Through Relay**

**Scott Walker, Governor**  
**Dave Ross, Secretary**

April 16, 2013

MASCO CORPORATION  
DELTA FAUCET  
MICHAEL MARTINEZ  
55 E 111TH ST.  
INDIANAPOLIS IN 46280

Re: Description: ALTERNATE PRODUCT REVIEW  
Manufacturer: MASCO CORPORATION  
Product Name: DELTA DST FAUCETS  
Model Number(s): ADDISON, ALORA, CASSIDY, CLASSIC, COLLINS, COMPEL, DRYDEN,  
FUSE, LAHARA, LELAND, LINDEN, PALO, PILAR, SIGNATURE, TRINSIC  
AND VICTORIAN  
Product File No: 20130068

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 382.40 (7) g 382.40 (7) h and 384.20 (6) c based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of April 2018.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This alternate approval is required because the supply connectors for these fixtures, which are integral to these fixtures, do not meet the general code requirements for length, dimension and temperature/pressure ratings. The integral supply connectors may only be used to install the fixtures models listed above.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter  
Plumbing Product Reviewer  
Department of Safety and Professional Services  
Division of Industry Services  
Bureau of Technical Services  
(608) 267-1401 Phone  
(608) 266-2602 Fax  
glen.schlueter@wi.gov E-mail