



May 9, 2013

KOHLER COMPANY
P & S P
DANIEL J. BARTZ
444 HIGHLAND DRIVE
KOHLER WI 53044

Re: Description: TRAP
Manufacturer: KOHLER COMPANY
Product Name: BATHROOM SINK BOTTLE TRAP
Model Number(s): K-9033
Product File No: 20130130

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 382.32 (3) (d), 382.32 (3) (f) 4. , Wis. Adm. Code based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of May 2018.

- The bottle trap shall be sized in accordance with SPS Table 382.30-1.
- The developed length between the vent and an installed bottle trap shall conform to SPS Table 382.31-1.
- The bottle trap materials of construction shall conform to SPS Table 384.30-1.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 266-2602 Fax
glen.schlueter@wi.gov E-mail