



July 19, 2013

KOHLER COMPANY
P & S P
DANIEL J. BARTZ
444 HIGHLAND DRIVE
KOHLER WI 53044

Re: Description: SHOWER ALTERNATE
Manufacturer: KOHLER COMPANY
Product Name: KOHLER SHOWER RECEPTORS 30" - 60"
Model Number(s): K-1936, K-1937, K9948, K-9949, K-9053 AND K-9054
Product File No: 20130165

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 384.20 (L) 4. based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of July 2018.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This approval allows for the shower receptor bases specified above to be sold and installed in Wisconsin despite the fact they are not capable of encompassing a 30-inch diameter circle.
- The finished shower compartment shall:
 1. have a minimum finished interior dimension ≥ 25 inches (in.);
 2. have a minimum cross-sectional area of $\geq 1,300$ in.²; and
 3. maintain the minimum area and dimensions specified in items 1 and 2 to a point 70 in. above the shower waste outlet with no protrusions other than fixture valves, showerheads, soap dishes retractable seats and grab bars.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail