



DIVISION OF INDUSTRY SERVICES
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor
Dave Ross, Secretary

August 14, 2013

TRI-COUNTY PRECAST, LLC
GARY F. JOHNSTON
2900 MARY ST
MARINETTE WI 54143

Re: Description: SEWAGE TREATMENT APPARATUS, TANK/CONTAINER ONLY
Manufacturer: TRI-COUNTY PRECAST, LLC
Product Name: FILTER CHAMBER
Model Number(s): 45 GAL.CAPACITY
[for use with Zabel filter models A100, A300 or A1800]
Product File No: 20130209

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of August 2018.**

This approval supersedes the approval issued on November 12, 2008 under product file number 20080616.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- When Zabel filter model A100, A300 or A1800 is installed in this tank, installation must be in accordance with the filter manufacturer's printed instructions and the filter's product approval stipulations. If there is a conflict between the filter manufacturer's printed instructions and the filter's product approval stipulations, the product approval stipulations will take precedence.
- The capacity of this filter chamber must not be included in the septic tank capacity required in ch. SPS 383.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

A handwritten signature in cursive script that reads 'Sally Shumaker'.

Sally A. Shumaker - POWTS Plan Reviewer/Plumbing Product Reviewer
Bureau of Technical Services
Division of Industry Services
Department of Safety and Professional Services
(608) 264-7782 Phone
(608) 267-9723 Fax
saly.shumaker@wisconsin.gov