



September 20, 2013  
(Revised Letter)

TUF-TITE INCORPORATED  
HARRY PLANDER  
1200 FLEX COURT  
LAKE ZURICH IL 60047

Re: Description: SEWAGE TREATMENT APPARATUS, EFFLUENT FILTER  
Manufacturer: TUF-TITE INCORPORATED  
Product Name: EFFLUENT FILTER  
Model Number(s): EF-6  
[MAX. DWF 1500 GPD]  
Product File No: 20130210

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of August 2018.**

This approval is contingent upon compliance with the following stipulation(s):

- An access opening of sufficient size to allow removal of the filter must be provided over the outlet tee baffle of which this product is installed. This access opening must terminate at or above grade.
- Maintenance information must be given to the owner of the tank explaining that periodic cleaning of the filter will be necessary.
- MAINTENANCE: The manufacturer recommends this unit be cleaned every time the tank is pumped or at least once every three years.
- This product may only be installed in the outlet tee of sewage treatment compartment or tank having a flow rate of no greater than 1500 GPD.
- Additional information is included as attachment(s) to this letter; see attachment A and B.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen A. Jones, M.S.  
POWTS Product Reviewer  
phone: (608) 267-5265  
fax: (608) 267-9723  
email: glen.jones@wi.gov