



August 14, 2013

CHAMPION, INC.  
READY MIX  
TONY SUSTARICH

PO BOX 490  
IRON MOUNTAIN MI 49801

Re: Description: SEWAGE TANKS, CONCRETE  
Manufacturer: CHAMPION, INC.  
Product Name: SEPTIC, HOLDING, GREASE INTERCEPTOR OR PUMP  
Model Number(s): 1000/500  
(42" L.L., 24/12 GAL./IN., 48" MAX. DEPTH OF BURY, 742 G.P.D. WHEN USED AS A SEPTIC/SEPTIC TANK OR 483 G.P.D. WHEN USED AS A SEPTIC/PUMP TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL WASTEWATER)  
Product File No: 20130235

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of August 2018.**

This approval supersedes the approval issued on August 28, 2008 under product file number 20080462.


This approval is contingent upon compliance with the following stipulation(s):

- This product is approved to use the following:
  - Four inch opening in access cover.
- This tank must be designed to withstand the pressures to which it will be subjected.
- When this product has an effluent filter installed in an interior wall, the space between the top of the interior wall and bottom of the tank's cover must be sealed with a material that will withstand the environment in the tank and in a manner that will prevent waste from passing over the interior wall.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 greater than 30 mg/L but less than or equal to 220 mg/L, TSS greater than 30 mg/L but less than or equal to 150 mg/L and F.O.G. less than or equal to 30 mg/L.
- The media used within this device is sacrificial, meaning that it will gradually dissolve over time and require regular replenishment to maintain a stable passivating layer and the treatment to remain effective.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

CHAMPION, INC.  
August 14, 2013  
Page 2 of 2  
Product File No.: 20130235

Sincerely,



Sally A. Shumaker - POWTS Plan Reviewer/Plumbing Product Reviewer  
Bureau of Technical Services  
Division of Industry Services  
Department of Safety and Professional Services  
(608) 264-7782 Phone  
(608) 267-9723 Fax  
sally.shumaker@wisconsin.gov