



DIVISION OF INDUSTRY SERVICES  
Plumbing Product Review  
P.O. Box 2658  
Madison, Wisconsin 53701-2658  
TTY: Contact Through Relay

Scott Walker, Governor  
Dave Ross, Secretary

August 14, 2013

MARSHFIELD WILBERT VAULT WORKS, INC.  
JEFFREY RASMUSSEN

PO BOX 493  
MARSHFIELD WI 54449

Re: Description: SEWAGE TREATMENT APPARATUS  
Manufacturer: MARSHFIELD WILBERT VAULT WORKS, INC.  
Product Name: BIO-MICROBICS SINGLE HOME FAST SYSTEM  
Model Number(s): 1300  
(0.75 or 0.9 MicroFAST)  
Product File No: 20130264

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of August 2018.**

This approval supersedes the approval issued on June 6, 2008 under product file number 20080283.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- This tank may only be installed in conjunction with the Bio-Microbics Inc., Single Home Fast sewage treatment apparatus.
- A sedimentation tank or compartment with a minimum capacity of 500 gallons must be located upstream of the tank or compartment in which the Bio-Microbics unit is installed.
- This product must be installed in accordance with the manufacturer's printed instructions, product approval and the plan approval. If there is a conflict between the manufacturer's instructions and the plan approval, the plan approval will take precedence.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

A handwritten signature in black ink that reads 'Sally Shumaker'.

Sally A. Shumaker - POWTS Plan Reviewer/Plumbing Product Reviewer  
Bureau of Technical Services  
Division of Industry Services  
Department of Safety and Professional Services  
(608) 264-7782 Phone  
(608) 267-9723 Fax  
sally.shumaker@wisconsin.gov