



October 4, 2013

RITZ-CRAFT CORP. OF MI, INC.
FRANK KRUSZKA
118 DEAL PKWY
JONESVILLE MI 49250

Re: Description: PREFABRICATED PLUMBING SYSTEM
Manufacturer: RITZ-CRAFT CORP. OF MI, INC.
Product Name: MODULAR HOME-DWV AND WATER LINES
Model Number(s): RANCH OR 2 STORY INSTALLATION OF: KITCHEN SINK WITH OR WITHOUT
DISHWASHER AND/OR FOOD WASTE GRINDER (KS1, KS2, KS3, KS4); TOILET (T1);
SINGLE BOWL VANITY OR UTILITY OR BAR SINK (VS1); WASHER BOX (WB1, WB2,
WB3); AND TUB SHOWER (TS1) SHOWER (TS2) TUB (TS3)
Product File No: 20130303

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of October 2018.

This approval is contingent upon compliance with the following stipulation(s):

1. SPS 382.20 (12). Install AAV's per approvals and stipulations.
 2. The maximum water supply fixture units (wsfu) on PEX tubing must not exceed 20.5 wsfu for 1-inch tubing, 11 wsfu for 3/4-inch tubing, 8 wsfu for 5/8-inch tubing, and 4 wsfu for 1/2-inch tubing. The maximum water supply fixture units (wsfu) on Type L copper tubing must not exceed 31.0 wsfu for 1-inch tubing, 16.5 wsfu for 3/4-inch tubing and 6.5 wsfu for 1/2-inch tubing.
- The flowing water supply pressure at the point(s) of connection must be at least 15 psig.
 - The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
 - This approval is for only the prefabricated plumbing system as defined herein. "Prefabricated Plumbing" means concealed drain piping, vent piping or water supply piping or a combination of these types of piping, contained in a modular building component, which will not be visible for inspection when delivered to the final site of installation.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

RITZ-CRAFT CORP. OF MI, INC.

Page 2

October 4, 2013

Sincerely,

Timothy J. Lamb
Plumbing Plan Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
Madison WI 53703-2658
608-266-9647 Phone
608-267-9723 Fax
tim.lamb@wi.gov E-mail