



November 8, 2013

MARSHFIELD WILBERT VAULT WORKS, INC.
JEFFREY RASMUSSEN
PO BOX 493
MARSHFIELD WI 54449

Re: Description: SEWAGE TREATMENT APPARATUS
Manufacturer: MARSHFIELD WILBERT VAULT WORKS, INC.
Product Name: BIO-MICROBICS MICRO FAST SYSTEM
Model Number(s): 728D
(0.5 MicroFAST)
[TANK DIMENSIONS (OD) = 96 IN. L X 48 IN. W X 64 IN. H]
Product File No: 20130347

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of November 2018.**

This approval supersedes the approval issued on 9/30/2008 under product file number 20080563.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- This tank may ONLY be installed in conjunction with the Bio-Microbics Inc., sewage treatment apparatus.
- A sedimentation tank or compartment with a minimum capacity of 350 gallons must be located up stream of the tank or compartment in which the Bio-Microbics, Inc. is installed.
- This product must be installed in accordance with the manufacturer's printed instructions, product approval and the plan approval. If there is a conflict between the manufacturer's instructions and the plan approval, the plan approval will take precedence.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S.
POWTS Product Reviewer
phone: (608) 267-5265
fax: (608) 267-9723
email: glen.jones@wi.gov