



February 19, 2014

ZURN INDUSTRIES INCORPORATED
ROBERT BURNHAM
1801 PITTSBURGH AVENUE
ERIE PA 16514

Re: Description: SIPHONIC ROOF DRAIN
Manufacturer: ZURN INDUSTRIES INCORPORATED
Product Name: ZURN SIPHONIC DRAIN
Model Number(s): Z130 AND Z131
Product File No: 20140002

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 382.36 based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of February 2019.

This approval supersedes the approval issued on June 30, 2008 under product file number 20080615.

This alternate approval is contingent upon compliance with the following stipulation(s):

- The roof drains must comply with ASME A112.6.9-2005.
- The design and installation of the siphonic roof drain must be in accord with ASPE technical Standard 45.
- All materials must comply with ASPE Technical Standard 45.
- Each siphonic roof drain and gutter drain shall be permanently marked at the dome, bodies, and baffle plates with the manufacturer name or trademark. The baffle plate and drain body shall also be marked with the baffle model number, resistance value, K, and words "REPLACE MISSING BAFFLE WITH MODEL _____." The marking shall be located at a location visible after installation.
- Plans and specification for siphonic roof drain systems must be approved by Department prior to installation of the system.
- Maintenance of the roof shall conform to ASPE Technical Standard 45

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail