



DIVISION OF INDUSTRY SERVICES
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor
Dave Ross, Secretary

March 5, 2014

TUF-TITE
TED MEYERS
1200 FLEX CT
LAKE ZURICH IL 60047-1570

Re: Description: SEWAGE TREATMENT APPARATUS
Manufacturer: TUF-TITE
Product Name: EFFLUENT FILTER
Model Number(s): EF-4
[MAX. DWF 800 GPD]
Product File No: 20140003

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of March 2019.**

This approval supersedes the approval issued on 4/13/2009 under product file number 20090152.

This approval is contingent upon compliance with the following stipulation(s):

- This product may only be installed in the outlet tee of sewage treatment compartment or tank having a flow rate of no greater than 800 GPD.
- A 1.25-in. hole must be drilled in the top of the filter within an inch of the slots provide for venting prior to being installed in the outlet tee.
- An access opening of sufficient size to allow removal of the filter must be provided over the outlet tee baffle of which this product is installed. This access opening must terminate at or above grade.
- Maintenance information must be given to the owner of the tank explaining that periodic cleaning of the filter will be necessary.
- MAINTENANCE: The manufacturer recommends this unit be cleaned every time the tank is pumped or at least once every three years.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S.
POWTS Product Reviewer
phone: (608) 267-5265
fax: (608) 267-9723
email: glen.jones@wi.gov