



SAFETY AND BUILDINGS DIVISION  
Plumbing Product Review  
P.O. Box 2658  
Madison, Wisconsin 53701-2658  
**TTY: Contact Through Relay**

**Scott Walker, Governor**  
**Dave Ross, Secretary**

March 7, 2014

STAR ENVIRONMENTAL INC.  
TIM ZOROMSKI  
705 THIRD ST  
PO BOX PO BOX 434  
MARATHON WI 54448

C&J CONCRETE WALLS, LLC  
CURVIN BRUBAKER  
W8498 CTH X  
THORP WI 54771

Re: Description: SEWAGE TANKS, SITE CONSTRUCTED  
Manufacturer: C&J CONCRETE WALLS, LLC  
Product Name: HOLDING TANK, SITE-CONSTRUCTED  
Model Number(s): 10,000  
[90 IN. L.L.; 109.7 GAL./IN.; ACTUAL CAPACITY 9874 GALS.; OUTSIDE DIMENSIONS =  
24 FT. X 9.4 FT.; ANTI-CORROSIVE EPOXY COATED]  
Product File No: 20140005

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 384.50 (2) based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of March 2019.**

This approval supersedes the approval issued on 5/15/2009 under product file number 20090139.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- Construction of this product must be designed and constructed in conformance with the specifications submitted and approved by this department and the sealant manufacturer's printed directions for use for the sealant materials.
- The manufacturer must keep a set of plans and specifications for this product bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S.  
POWTS Product Reviewer  
phone: (608) 267-5265  
fax: (608) 267-9723  
email: glen.jones@wi.gov