



April 22, 2014

THE HUBSCRUB COMPANY
REHABILITATION EQUIPMENT ASSOCIATES INC.
KARL SODERQUIST
1015 CANDIA ROAD
MANCHESTER NH 03109

Re: Description: HEALTH CARE PLUMBING APPLIANCE
Manufacturer: THE HUBSCRUB COMPANY
Product Name: HUBSCRUB
Model Number(s): 20/70 RTU
Product File No: 20140045

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of April 2019.

This approval is contingent upon compliance with the following stipulation(s):

- A Watts LF009QT reduced pressure zone (RPZ) assembly shall be installed on the water supply piping serving this device. This is required because the device does not contain acceptable integral cross connection control.

This is the method and manufacturer selected by the Hubscrub Company.

- The RPZ shall be installed in accordance with s. SPS 382.41 (5) (b) – (g) and conform to ASSE Standard 1013.
- The drain, waste and vent (DWV) system serving this device shall be properly sized to accept the anticipated wastewater loading due to these devices and comprised of piping materials which are acceptable for contact with the maximum wastewater temperature generated by these devices.
- A hose connection vacuum breaker (ASSE 1011) is not an acceptable means of cross connection control because the device is subject to a continuous pressure situation.
- The stipulations of approval listed above must be maintained when these mobile devices are moved from site to site.
- The water fill hose shall conform to s. SPS 384.20 (6) (c).
- The drain hose shall conform to Table 384.30-5.

The Hubscrub Company
April 22, 2014
Page 2 of 2
Product File No.: 20140045

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail