



SAFETY AND BUILDINGS DIVISION  
Plumbing Product Review  
P.O. Box 2658  
Madison, Wisconsin 53701-2658  
**TTY: Contact Through Relay**

**Scott Walker, Governor**  
**Dave Ross, Secretary**

April 30, 2014

ECOLAB, INC.  
REGULATORY AFFAIRS  
JAMISON KORTAS  
370 N. WABASHA ST.  
ST. PAUL MN 55102-1390

ECOLAB, INC.  
INSTITUTIONAL  
ANI SEUMALO  
370 N. WABASHA ST.  
ST. PAUL MN 55102

Re: Description:       PROPORTIONER  
Manufacturer:       ECOLAB, INC.  
Product Name:       ECOLAB SOLID PRODUCT DISPENSERS FOR COMMERCIAL DISHMACHINES  
Model Number(s):   WASH MAX; KLENE VIEW AND RINSE MAX II  
Product File No:    20140058

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 384.20 (5) (d) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of April 2019.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This alternate approval allows for the use of chemical proportioners that are not listed under ASSE Standard 1055.
- This alternate approval is contingent upon the Wash Max and Klene View models being installed using the Watts 288A atmospheric vacuum breaker (AVB). The Rinse Max model is installed using the Ecolab A25-F AVB. Both the Watts 288A and Ecolab A-25F AVBs conform to ASSE 1001 and are listed by ASSE. The AVBs must be installed in accordance with s. SPS 382.41 (4) (b) 1.
- All proportioners shall be installed in accordance with 382.41 (5) (k).

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter  
Environmental Engineer - Plumbing Product Reviewer  
Department of Safety and Professional Services  
Division of Industry Services  
Bureau of Technical Services  
(608) 267-1401 Phone  
(608) 267-9723 Fax  
glen.schlueter@wi.gov E-mail