



June 4, 2014

TERRACE HOMES  
MARK WIEDMEYER  
1553 11TH DR  
FRIENDSHIP WI 53934

Re: Description: PREFABRICATED PLUMBING SYSTEM  
Manufacturer: TERRACE HOMES  
Product Name: PREFABRICATED PLUMBING SYSTEM  
Model Number(s): THGS 02  
Product File No: 20140122

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of June 2019.

This approval is contingent upon compliance with the following stipulation(s):

- The maximum water supply fixture units (wsfu) on PEX tubing must not exceed 20.5 wsfu for 1-inch tubing, 11 wsfu for 3/4-inch tubing, 8 wsfu for 5/8-inch tubing, and 4 wsfu for 1/2-inch tubing.
- The maximum water supply fixture units (wsfu) on Type M copper tubing must not exceed 112.0 wsfu for 1-1/2-inch tubing, 62.0 wsfu for 1-1/2-inch tubing, 34.0 wsfu for 1-inch tubing, 18.0 wsfu for 3/4-inch tubing and 7.5 wsfu for 1/2-inch tubing.
- The flowing water supply pressure at the point(s) of connection must be at least 28 psig.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- This approval is for only the prefabricated plumbing system as defined herein. "Prefabricated Plumbing" means concealed drain piping, vent piping or water supply piping or a combination of these types of piping, contained in a modular building component, which will not be visible for inspection when delivered to the final site of installation.
- Please send in current drawings with a copy of this approval letter.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

TERRACE HOMES

Page 2

June 4, 2014

Sincerely:

Timothy J. Lamb  
Plumbing Plan Reviewer  
Department of Safety and Professional Services  
Division of Industry Services  
Bureau of Technical Services  
Madison WI 53703-2658  
608-266-9647 Phone  
608-267-9723 Fax  
tim.lamb@wi.gov E-mail