



June 12, 2014

REVISED COPY

APOLLO CORPORATION  
STEVE ROKOS  
450 MAIN ST  
PO BOX 219  
SOMERSET WI 54025

Re: Description: HEALTH CARE PLUMBING APPLIANCE  
Manufacturer: APOLLO CORPORATION  
Product Name: ADVANTAGE BATHING SYSTEMS  
Model Number(s): WP6000, WP6300, AS6000, AS6300, SS-WP6000, SS-AS6000, SS-WP6300  
AND SS-AS6300  
Product File No: 20140145

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of June 2019.

This approval supersedes the approval issued on October 2, 2008 under product file number 20080566..

This approval is contingent upon compliance with the following stipulation(s):

- The hand held shower must remain protected by ASSE 1014 compliant vacuum breakers.
- The chemical dispensing system must remain protected by ASME A112.18.3 compliant dual check valves.
- A floor drain shall be installed within 6 feet of the tub door.
- When this product discharges waste through indirect waste piping, the waste must discharge to an acceptable receptor in accordance with s. SPS 382.33 (8) of the Wis. Adm. Code.
- Installation and maintenance of this product must be in accordance with the manufacturer's printed installation and maintenance instructions.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter  
Environmental Engineer - Plumbing Product Reviewer  
Department of Safety and Professional Services  
Division of Industry Services  
Bureau of Technical Services  
(608) 267-1401 Phone  
(608) 267-9723 Fax  
glen.schlueter@wi.gov E-mail