



June 24, 2014

WATER SAVER FAUCET COMPANY
MIKE STRAUGHN
701 W ERIE ST
CHICAGO IL 60610

Re: Description: VACUUM BREAKER, LABORATORY FAUCET - ASSE 1035
Manufacturer: WATER SAVER FAUCET COMPANY
Product Name: WATERSAVER IN-LINE VACUUM BREAKER
Model Number(s): L7110
Product File No: 20140157

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 384.11 based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of June 2019.

This alternate approval is required because the product is not listed by a nationally recognized listing agency acceptable to this department.

This approval supersedes the approval issued on March 13, 2007 under product file number 20060524.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product may only be installed under the following conditions:
 1. Cold water applications ($\leq 85^{\circ}\text{F}$);
 2. The inlet pressure to this product shall be ≤ 80 psig; and
 3. Not be exposed to backpressure > 2.6 psig (i.e. 6 feet of water column).

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail