



SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor
Dave Ross, Secretary

July 2, 2014

DEPT. OF SAFETY AN PROFESSIONAL SERVICES
BUREAU OF TECHNICAL SERVICES
DIVISION OF INDUSTRY SERVICES
THOMAS BRAUN - SECTION CHIEF
1400 E WASHINGTON AVE
MADISON WI 53703

Re: Description: ALTERNATE SYSTEM
Manufacturer: DEPT. OF SAFETY AN PROFESSIONAL SERVICES
Product Name: INSTALLATION OF VENTLESS BACKFLOW PREVENTION DEVICES IN
UNINHABITABLE SPACES SUSCEPTIBLE TO FLOODING
Model Number(s): NONE
Product File No: 20140215

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 382.41 (5) (d) 1 based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of July 2019.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This approval permits the installation of a cross connection control device that does not incorporate a vent port to be installed in an uninhabited location susceptible to flooding.
- All cross connection control devices must be installed in accordance with the manufacturer's published instructions and ch. SPS 381-384 Wis. Adm. Code. If there is a conflict, then the Wis. Adm. Code shall take precedence.
- Cross connection control devices may not be installed in areas subject to freezing.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Thomas Braun – Section Chief
Department of Safety and Professional Services
Bureau of Technical Services
Division of industry Services
Phone: 608-266-8981
Fax: 608-267-9723
Email: thomas.braun@wisconsin.gov