



October 14, 2014

KES SCIENCE AND TECHNOLOGY INC.
CHERRI SPEARMAN
3625 KENNESAW NORTH INDUSTRIAL PARKWAY
KENNESAW GA 30144

Re: Description: MISTING SYSTEM, ALTERNATE PLUMBING SYSTEM
Manufacturer: KES SCIENCE AND TECHNOLOGY INCORPORATED
Product Name: PRODUCE MISTING SYSTEM
Model Number(s): EDGE, CALIBER AND MIST CONTROL
Product File No: 20140301

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of October 2019.

This approval supersedes the approval issued on October 13, 2009 under product file number 20090371.

This alternate approval is contingent upon compliance with the following stipulation(s):

- The use of this system must conform to all applicable United States Food and Drug Administration (USFDA), Wisconsin Department of Agriculture, Trade and Consumer Protection (DATCP) and other governing regulatory agency requirements.
- The black and/or white 1/2 inch and 1 inch PVC tubing may be installed for the following water uses:
 - a. Overhead inter-misting head water distribution piping above ground cold only
 - b. Below flood level rim of case, inter-misting head water distribution piping above ground cold only
- The black and/or white 1/2 inch and 1 inch PVC tubing used in this system must be labeled with the KES Science & Technology logo, KES company name or the actual tubing manufacturers name, nominal tubing size, pressure rating and the statement "for cold water supplies only". In addition, all tubing must conform to NSF Standard 51 for aqueous food or NSF Standard 61 for potable water contact.
- This product must be installed and joints made in accordance with the manufacturer's published instructions (i.e. KES_Edge_Quick_Connect_Manual_2.cdr 05/09/03).

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail