



March 31, 2015

PENNER MFG.INC.
PATRICK WALL
102 GRANT ST
PO BOX 503
AURORA NE 68818

Re: Description: HEALTH CARE PLUMBING APPLIANCE
Manufacturer: PENNER MFG.INC.
Product Name: CASCADE BATHING SYSTEMS
Model Number(s): CASCADE SERIES 360000, 360010, 361910, 362010, 370000 AND 360020
Product File No: 20150044

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of March 2020.

This approval supersedes the approval issued on January 10, 2014 under product file number 20130382.

No external cross connection control is required for these devices because they contain an acceptable level of integral cross connection control. Specifically:

1. The influent water lines are protected by air gaps that conform to ASME A112.1.2;
2. the influent cold water lines are protected by vacuum breakers that conform to ASSE 1001;
3. the hand showers/sprays are protected by vacuum breakers that conform to CSA B64.8; and
4. the devices contain a series of check valves.

Note, no cross connection control credit was given for the check valves.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Dept of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail