



October 6, 2015

B & B CHLORINATION  
MIKE BEHRENS  
PO BOX 246  
ALBERT CITY, IA 50510

Re: Description: WATER TREATMENT CHEMICAL INJECTION DEVICE  
Manufacturer: B & B CHLORINATION  
Product Name: DRY PELLET CHLORINATOR (trans id 2567772)  
Model Number(s): MARK III  
Product File No: 20150178

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of October 2020.

This approval supersedes the approval issued on October 1, 2010 under product file number 20100111.

This approval is contingent upon compliance with the following stipulation(s):

- If these approved devices are modified or additional assertions of function or performance are made, then this approval shall be considered null and void, unless the change is submitted to the department for review and the approval is reaffirmed.
- Only dry chlorine pellets, Environmental Protection Agency Registration number 53026-1, weighing one gram, 3/8-inch diameter, may be used with this product.
- These devices may not be used to treat wells that are known to be microbiologically unsafe.
- An approved drop tube assembly with at least 0.75 in.<sup>2</sup> vented surface shall be used. Order B&B's Wisconsin drop tube assembly.
- The drop tube shall extend below the pitless adapter.
- The drop tube shall have a minimum of 20 smooth, equally spaced, bore vent holes on the lower half of the drop tube.
- The drop tube shall have a tapered end to promote moisture release.
- This product has undergone sufficient testing to document the product's ability to properly inject a chemical into a water supply system as specified in this approval letter.
- For buildings not served by a municipal water supply, Department of Natural Resources (DNR) written approval may be required prior to installation of this product to inject a chemical into a water supply system. For more information contact the DNR Private Water Systems Section, P.O. Box 7921, Madison, WI 53707, telephone (608) 267-9787.

B&B Chlorination  
October 6, 2015  
Page 2 of 2  
Product File 20150178

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter  
Environmental Engineer - Plumbing Product Reviewer  
Dept of Safety and Professional Services  
Division of Industry Services  
Bureau of Technical Services  
(608) 267-1401 Phone  
(608) 267-9723 Fax  
glen.schlueter@wi.gov E-mail