



October 08, 2015

CUST ID No. 1323442

STEVE DAVIS  
AK INDUSTRIES INC  
PO BOX 640  
PLYMOUTH IN 46563

**PLAN APPROVAL EXPIRES: 10/31/2020**

Re: Description: SEWAGE TANKS, POLYETHYLENE  
Manufacturer: AK INDUSTRIES, INC.  
Product Name: SEPTIC TANK (trans id 2602116)  
Model Number(s): 1500  
(59.5 IN. L.L., 36 IN. MAX. DEPTH OF BURY, 720 G.P.D. WHEN USED AS A SEPTIC TANK BASED ON A 3-YR. SERVICE INTERVAL FOR RESIDENTIAL WASTEWATER; TANK DIMENSIONS (OD) = 113 7/16 IN. L X 59 IN. W X 59 IN. H)  
Product File No: 20150228

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of October 2020.**

This approval supersedes the approval issued on 1/20/2011 under product file number 20110028.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- Installation and servicing of this product must be in accordance with the manufacturer's instructions. A copy of the manufacturer's installation and servicing instructions must be given to the owner of the system.
- The inlet, outlet and tees must be schedule 40 PVC conforming to ASTM standard D2665 or D1785.
- The tees must be located between the end wall of the tank and center line of the manhole on the same end of the tank.
- The tees must be installed so that they extend a minimum six inches above the liquid level, nine inches below the liquid level but not more than 1/3 below the liquid level of the tank and have at least two inches of clearance between the top of the tee and the tank.

Identification Numbers
<b>Transaction ID No. 2602116</b>
<b>Site ID No.</b>
Please refer to both identification numbers, above, in all correspondence with the agency.

- The tees must be located between the end wall and the center line of the manhole on one end of the tank and between the end wall and the center line of the 10 inch observation pipe on the other end of the tank.
- This product may not be installed more than 36 inches below final grade.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 greater than 30 mg/L but less than or equal to 220 mg/L, TSS greater than 30 mg/L but less than or equal to 150 mg/L and F.O.G. less than or equal to 30 mg/L.
- BACKFILL: Course sand or fine gravel backfill of ½ in. or smaller must be used and completely surround and cover the tank within one-foot or less of the ground surface.
- BEDDING: Compacted aggregate conforming to tank base at depth and diameter as per manufacturer's installation instructions; dewater excavation prior to installation.
- LIDS AND RISERS: Romar risers/lids and covers available in variable heights.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S.  
POWTS Product Reviewer  
phone: (608) 267-5265  
fax: (608) 267-9723  
email: glen.jones@wi.gov

The DSPS is committed to service excellence. Visit our survey at:

[www.surveymonkey.com/s/dspsiscustomersatisfaction](http://www.surveymonkey.com/s/dspsiscustomersatisfaction)