

INDUSTRY SERVICES

NOV 19 2015

RECEIVED

Burial Requirements: 4 feet or less of cover for standard lids
 4 feet to 6 feet will require a 8" lid
 6 feet is the max depth with 8" lid

locking method (plastic riser) -
 use the supplied screws to lock the lid to the riser
 locking method (concrete riser) -
 use 1/4" chain and loop it thru the lid hoop and riser loop then lock

toxic labels are clearly marked on top of each manhole cover


Proper bedding and back filling -
 -Tanks need to be bed with adequate sand and or sewer stone capable of bearing the weight of the tank and all of its contents. There must be at least 3" of sand between the tanks and bedrock.
 -Tanks need to be back filled with a sandy material with minimal clay and no large rocks.

Conditionally
 APPROVED

[Signature]

SEE CORRESPONDENCE

Description: 2000 gal	Designer: JTN
	Date: 9/15/15
Owner: Iron City Enterprises (906) 863-5987	Scale: Noted
	Sheet # 1 of 2



24" Polyloc risers and filters are used on our tanks **B**

HLM 5000 water proofing membrain can be provided
it will be sprayed on per request

inlit and oulit concrete plugs can be provided upon request

total gallons = 2566

Gallons per Vertical inch = 46

Burial Requirements: 4 feet or less of cover for standard lids
4 feet to 6 feet will require a 8" lid
6 feet is the max depth with 8" lid

locking method (plastic riser) -
use the suplied screws the lock the lid to the riser
locking method (concrete riser) -
use 1/4" chain and loop it thru the lid hoop and riser loop then lock

toxic labels are clearly marked on top of each manhole cover

Proper bedding and back filling -
-Tanks need to be bed with adequate sand and or sewer stone capable
of bearing the weight of the tank and all of its contents. There must be
at least 3" of sand between the tanks and bedrock.
-Tanks need to be back filled with a sandy material with minimal clay and no large rocks.



**Conditionally
APPROVED**

Steve Jones
SEE CORRESPONDENCE

Description: 2000 gal	Designer: JTN
	Date: 9/15/15
Owner: Iron City Enterprises (906) 863-5987	Scale: Noted
	Sheet # 2 of 2

RECEIVED
NOV 19 2015

INDUSTRY SERVICES



material = 1/4" black abs poly

Left view
Scale: 1:4

Front view
Scale: 1:4

**Conditionally
APPROVED**

[Signature]
SEE CORRESPONDENCE

Description: standard baffle	Designer: JTN
	Date: 1/8/14
Owner: Iron City Enterprises (906) 863-5987	Scale: Noted
	Sheet # 1 of 1

RECEIVED
 NOV 19 2015
 INDUSTRY SERVICE