



Scott Walker, Governor
Dave Ross, Secretary

December 09, 2015

Identification Numbers
Transaction ID No. 2637312
Site ID No.
Please refer to both identification numbers, above, in all correspondence with the agency.

CUST ID No. 1335825

MICHAEL MASON
DESIGN HOMES INC
600 N MARQUETTE RD PO BOX 239
PRAIRIE DU CHIEN WI 53821

CONDITIONAL APPROVAL
PLAN APPROVAL EXPIRES: 12/31/2020

Re: Description: PREFABRICATED PLUMBING SYSTEM
Manufacturer: DESIGN HOMES, INC.
Product Name: PLUMBING DETAIL #2 (trans id 2637312)
Model Number(s): P-2
Product File No: 20150279

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of December 2020.

This approval is contingent upon compliance with the following stipulation(s):

- The flowing water supply pressure at the point(s) of connection must be at least 20 psig.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- This approval is for only the prefabricated plumbing system as defined herein. "Prefabricated Plumbing" means concealed drain piping, vent piping or water supply piping or a combination of these types of piping, contained in a modular building component, which will not be visible for inspection when delivered to the final site of installation.
- The maximum water supply fixture units (wsfu) on PEX tubing must not exceed 20.5 wsfu for 1-inch tubing, 11 wsfu for 3/4-inch tubing, 8 wsfu for 5/8-inch tubing, and 4 wsfu for 1/2-inch tubing.

This approval supersedes the approval issued on 11-9-2010 under product file number 20100462.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Timothy J. Lamb
Plumbing Plan Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
Madison WI 53703-2658
608-266-9647 Phone
608-267-9723 Fax
tim.lamb@wi.gov E-mail

Fee Required \$	125.00
Fee Received \$	125.00
Balance Due \$	0.00

WiSMART code: 7657