



Scott Walker, Governor
Dave Ross, Secretary

February 03, 2016

Identification Numbers
Transaction ID No. 2657446
Site ID No.
Please refer to both identification numbers, above, in all correspondence with the agency.

CUST ID No. 1320179

MARK WIESER
WIESER CONCRETE PRODUCTS INC
2815 RILEY ROAD
PORTAGE WI 53901

PLAN APPROVAL EXPIRES: 02/28/2021

Re: Description: SEWAGE TREATMENT APPARATUS & TANK SYSTEM [SEE STA -SEWAGE TREATMENT APPARATUS]
Manufacturer: WIESER CONCRETE PRODUCTS, INC.
Product Name: MICRO FAST 3.0 OR HIGHSTRENGTH FAST 3.0 (trans id 2657446)
Model Number(s): W2700 BIO WITH INSERT MICRO FAST 3.0 OR HIGHSTRENGTH FAST 3.0 (3000 GPD)

[64 IN. L.L.; 96 IN. MAX. DEPTH OF BURY; TANK DIMENSIONS (OD) = 145 3/8 IN. L X 79 1/4 IN. W X 82 1/8 IN. H; SEE MAX. BOD IN LBS./DAY AND MAINTENANCE INTERVAL FOR BIO MICROBICS MICRO FAST AND HIGH STRENGTH FAST 3.0 UNITS AS SEPARATE APPROVALS]

Product File No: 20160016

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of February 2021.**

This approval supersedes the approval issued on 1/12/2011 under product file number 20110020.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- Installation and servicing of this product must be in accordance with the manufacturer's instructions. A copy of the manufacturer's installation and servicing instructions must be given to the owner of the system.
- This product must be installed in accordance with the manufacturer's printed instructions, product approval and the plan approval. If there is a conflict between the manufacturer's instructions and the plan approval, the plan approval will take precedence.

- This tank may only be used in conjunction with the Bio-Microbics Inc., Micro Fast 3.0 or High Strength Fast 3.0 units.
- Also refer to the department's product approval stipulations for the sewage treatment apparatus, which may include: maximum daily wastewater flow, influent strength, maximum BOD5, and maintenance intervals.
- To determine treatment credits for residential and commercial POWTS designs, see stipulations regarding max. BOD5, DWF, approved effluent filters, etc. contained in approval letters for the specific treatment device.
- **BEDDING:** Bedding must be capable of bearing the weight of the tank. Bedding material must have the ability for 100% to pass through 3/4 inch screen. Bedding thickness must be 4 inches minimum compacted (thickness may vary due to soil conditions).
- **BACKFILL:** Sidewalls of tanks must have dry backfill materials that have the ability to pass 100% through a 2-inch screen. Provide a min. 12 inches on all sides from bottom to top, placed with a backhoe or concrete bucket to avoid impact loads on sidewall of tank. No compaction of backfill material is permitted on sidewalls; if more than 85% modified Proctor compaction is required, then use 3/8- or 3/4-inch washed gravel for backfill material.
- Additional information is included as attachment(s) to this letter; see attachment A.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S.
POWTS Product Reviewer
phone: (608) 267-5265
fax: (608) 267-9723
email: glen.jones@wi.gov

The DSPS is committed to service excellence. Visit our survey at:

www.surveymonkey.com/s/dspscustomersatisfaction