



Scott Walker, Governor
Dave Ross, Secretary

February 04, 2016

Identification Numbers
Transaction ID No. 2658816
Site ID No.
Please refer to both identification numbers, above, in all correspondence with the agency.

CUST ID No. 1340498

GARY KOTESKEY
SIM TECH FILTER
6598 HORTON BAY N RD
BOYNE CITY MI 49712

PLAN APPROVAL EXPIRES: 02/28/2021

Re: Description: SEWAGE TREATMENT APPARATUS, EFFLUENT FILTER
Manufacturer: SIM / TECH FILTER
Product Name: GAG SIM/TECH FILTER (trans id 2658816)
Model Number(s): STF-100, STF-100A, STF-100A2 AND STF-100A3
[>1/16 IN. FILTRATION; INSTALL SINGLY OR IN MULTIPLES]
Product File No: 20160021

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of February 2021.**

This approval supersedes the approval issued on 12/6/2010 under product file number 20100474.

This approval is contingent upon compliance with the following stipulation(s):

- Installation and servicing of this product must be in accordance with the manufacturer's instructions. A copy of the manufacturer's installation and servicing instructions must be given to the owner of the system.
- An access opening of sufficient size to allow removal of the filter must be provided over the outlet tee baffle of which this product is installed. This access opening must terminate at or above grade.
- Maintenance information must be given to the owner of the tank explaining that periodic cleaning of the filter will be necessary.
- The sizing calculations of the pressure distribution network must include 0.5 feet head loss for this product.
- Installation recommends minimum 2-in. diameter frost protected force main; sch. 80 union, and adequate access for installation and maintenance. Device has permanently affixed label: Gag SIM/TECH Filter.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S.; POWTS Product Reviewer
phone: (608) 267-5265; fax: (608) 267-9723
email: glen.jones@wi.gov

The DSPPS is committed to service excellence. Visit our survey at:
www.surveymonkey.com/s/dspsiscustomersatisfaction