



February 12, 2016

Identification Numbers
Transaction ID No. 2662629
Site ID No.
Please refer to both identification numbers, above, in all correspondence with the agency.

CUST ID No. 1341468

GARY BUTLER
THE COMMODORE CORPORATION
1423 LINCOLNWAY EAST PO BOX 577
GOSHEN IN 46526

CONDITIONAL APPROVAL
PLAN APPROVAL EXPIRES: 02/29/2021

Re: Description: PREFABRICATED PLUMBING SYSTEM
Manufacturer: COMMODORE HOMES OF INDIANA
Product Name: PREFABRICATED PLUMBING SYSTEM (trans id 2662629)
Model Number(s): TYPICAL PLUMBING
Product File No: 20160025

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of February 2021.

This approval is contingent upon compliance with the following stipulation(s):

Key Items:

1. **SPS 82.33(9)(c)(1)a.** A standpipe receptor may not extend more than 36 inches nor less than 18 inches above the centerline of the trap outlet. **SPS 382.33(9)(c)(1)b.** A standpipe receptor shall terminate at least 26 inches but not more than 48 inches above the floor on which the clothes washer is located.
2. **SPS 382.35(3)(i).** Double sanitary tees. A cleanout shall be provided immediately above or below a double sanitary tee drain fitting which is installed in a vertical drain pipe of less than 3" in diameter, unless a stack cleanout is provided in accordance with par. (f).
3. **SPS 382.31(10)(c).** A horizontal drain served by a circuit vent may not diminish in size from the most downstream fixture drain connection vented by the circuit vented drain to the circuit vent connection.
4. **SPS 382.35(3)(a)** All gravity horizontal drains within or under a building shall be accessible through a cleanout in accordance with one of the following requirements.
5. **SPS 382.33(8).** A receptor receiving the discharge from indirect waste piping or local waste piping shall be of a shape and capacity as to prevent splashing or flooding. Receptors shall be installed in accordance with this subsection and shall be accessible.

Reminder:

- The flowing water supply pressure at the point(s) of connection must be at least 47 psig.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- This approval is for only the prefabricated plumbing system as defined herein. "Prefabricated Plumbing" means concealed drain piping, vent piping or water supply piping or a combination of these types of piping, contained in a modular building component, which will not be visible for inspection when delivered to the final site of installation.
- This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20110170.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Timothy J. Lamb
Plumbing Plan Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
Madison WI 53703-2658
608-266-9647 Phone
608-267-9723 Fax
tim.lamb@wi.gov E-mail

Fee Required \$	125.00
Fee Received \$	125.00
Balance Due \$	0.00

WiSMART code: 7657