



**Scott Walker, Governor**  
**Dave Ross, Secretary**

March 28, 2016

Identification Numbers
<b>Transaction ID No. 2676483</b>
<b>Site ID No.</b>
Please refer to both identification numbers, above, in all correspondence with the agency.

CUST ID No. 1332792

HUBERT MCQUESTION  
LAKE SHORE BURIAL VAULT CO INC  
12780 LISBON RD  
BROOKFIELD WI 53005

**PLAN APPROVAL EXPIRES: 03/31/2021**

Re: Description: SEWAGE TANKS, CONCRETE  
Manufacturer: LAKE SHORE BURIAL VAULT CO., INC.  
Product Name: (trans id 2676483) SEPTIC/SEPTIC, SEPTIC/PUMP, HOLDING, OR PUMP  
Model Number(s): 3350/1650 (5000 GAL. 2-COMPARTMENT)

(61 IN. L.L., 54.92/27.05 GAL/IN., 96 IN. MAX. DEPTH OF BURY, 2394 G.P.D. WHEN USED AS A SEPTIC/SEPTIC TANK OR 1604 G.P.D. WHEN USED AS A SEPTIC/PUMP TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL WASTEWATER; TANK DIMENSIONS (OD) = 230 IN. L X 98 IN. W X 80 IN. H)

Product File No: 20160065

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of March 2021.**

This approval supersedes the approval issued on 4/18/2011 under product file number 20110120.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product has an effluent filter installed in an interior wall, the space between the top of the interior wall and bottom of the tank's cover must be sealed with a material that will withstand the environment in the tank and in a manner that will prevent waste from passing over the interior wall.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 greater than 30 mg/L but less than or equal to 220 mg/L, TSS greater than 30 mg/L but less than or equal to 150 mg/L and F.O.G. less than or equal to 30 mg/L.

- When the optional side inlets and/or outlets located along the side of the tank within 21 inches of the outside corner of the tank are used in this product as a septic tank, the inlet and outlet may not be located at the same end of the tank.
- BEDDING: For tanks under 2,000 gal. capacity, a minimum of 3 inches of sand or stone must be used. When sand is used, excavation must be made to prevent sand from washing out under the tank. Stones the size of #2 and under are acceptable.
- BACKFILL: When cover is greater than 48 in., backfill around tank with material described in BEDDING stipulation.
- An optional 8 in. diameter inlet may be located at the end of tank or through the tank cover. When located at end wall, location shall be below manhole opening. When located through cover, location shall be no greater than 20 inches from sidewall.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S.  
POWTS Product Reviewer  
phone: (608) 267-5265  
fax: (608) 267-9723  
email: glen.jones@wi.gov

The DSPS is committed to service excellence. Visit our survey at:

[www.surveymonkey.com/s/dspscustomersatisfaction](http://www.surveymonkey.com/s/dspscustomersatisfaction)