



Scott Walker, Governor
Dave Ross, Secretary

March 28, 2016

Identification Numbers
Transaction ID No. 2679270
Site ID No.
Please refer to both identification numbers, above, in all correspondence with the agency.

CUST ID No. 1148587

MARK DENFELD
6702 CLOVER ROAD
WAUSAU WI 54401-9251

PLAN APPROVAL EXPIRES: 03/31/2021

Re: Description: SEWAGE TANKS, SITE CONSTRUCTED (voluntary)
 Manufacturer: DENFELD CONSTRUCTION, INC.
 Product Name: (trans id 2679270) HOLDING
 Model Number(s): 4308, 4608, 4742, 5505, 6096, 10161
 (4308 - 89.75 GAL/IN, 4608 - 69.82 GAL/IN, 4742 - 69.74 GAL/IN, 5505 - 79.78 GAL/IN, 6096 - 89.55 GAL/IN, 10161- 149.43 GAL/IN, ALL TANKS -96 IN. MAX. DEPTH OF BURY; TANK DIMENSIONS--see below)
 Product File No: 20160072

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of March 2021.**

This approval supersedes the approval issued on 8/10/2011 under product file number 20110251.

This approval is contingent upon compliance with the following stipulation(s):

- TANK DIMENSIONS (BY MODEL/CAPACITY IN GALS.): 4,308: 18 FT. L X 8 FT. W X 4 FT. H; 4,608: 14 FT. L X 8 FT. W X 5.5 FT. H; 4,742: 14 FT. L X 8 FT. W X 5.66 FT. H; 5,505: 16 FT. L X 8 FT. W X 5.75 FT. H; 6096: 18 FT. L X 8 FT. W X 5.66 FT. H; AND 10,161: 30 FT. L X 8 FT. W X 5.75 FT. H.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- Construction of this product must be designed and constructed in conformance with the specifications submitted and approved by this department and the sealant manufacturer's printed directions for use for the sealant materials.
- The manufacturer must keep a set of plans and specifications for this product bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.

- This product is approved to use the following:
 - The inlet location may be lower than the listed liquid level specified for this product.
 - Optional EZ Set synthetic risers and riser covers.
- BACKFILL: Material must contain no stones or debris larger than 3 inches in diameter; place in uniform layers no larger than 24 inches. When night-time temperatures are above 40 degrees F, tanks may be backfilled 5-7 days after tank cover has been poured or installed. When night-time temperatures are below 40 degrees F, tanks may be backfilled 5-7 days after tank cover has been poured or installed.
- BEDDING: Provide a min. of 4 inches of bedding below tank. Material consists of ¾-in. washed rock.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S.
POWTS Product Reviewer
phone: (608) 267-5265
fax: (608) 267-9723
email: glen.jones@wi.gov

The DSPS is committed to service excellence. Visit our survey at:

www.surveymonkey.com/s/dspsiscustomersatisfaction