



SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor
Dave Ross, Secretary

March 11, 2016

DEPT. OF SAFETY AN PROFESSIONAL SERVICES
INDUSTRY SERVICES
THOMAS BRAUN - SECTION CHIEF
1400 E WASHINGTON AVE
MADISON WI 53703

Re: Description: ALTERNATE SYSTEM
Manufacturer: DEPT. OF SAFETY AN PROFESSIONAL SERVICES
Product Name: DFU ASSIGNMENT TO RECEPTORS OF INDIRECT WASTE, AND DRAIN SYSTEM(S)
Model Number(s): NONE
Product File No: 20160077

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 382.30 (3)(a) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of March 2021.

This approval supersedes the approval issued on February 17, 2011 under product file number 20110053.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This approval applies to receptors that only receive discharge from refrigerated food display cases.
- The trap size for receptors of indirect waste serving refrigerated food display cases under this alternate system shall be 2 to 4 inches.
- The drainage fixture unit value assigned to each receptor of indirect waste serving refrigerated food display cases is two.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Thomas Braun
Section Chief
Industry Services
Dept. of Safety and Professional Services
Phone: 715-634-5124
Email: thomas.braun@wisconsin.gov