



Scott Walker, Governor
Dave Ross, Secretary

March 29, 2016

Identification Numbers
Transaction ID No. 2685288
Site ID No.
Please refer to both identification numbers, above, in all correspondence with the agency.

CUST ID No. 1345620

RUSS MARTI
STRATFORD HOMES LP
402 S WEBER AVE PO BOX 37
STRATFORD WI 54484

CONDITIONAL APPROVAL
PLAN APPROVAL EXPIRES: 03/31/2021

Re: Description: PREFABRICATED PLUMBING SYSTEM
Manufacturer: STRATFORD HOMES L.P.
Product Name: (trans id 2685288) MOTEL SLEEPING ROOMS
Model Number(s): A1 w/ COMMON AREA, A2 w/COMMON AREA, A3 w/COMMON AREA, A4 w/COMMON AREA, A5 w/COMMON AREA AND A6 w/COMMON AREA
Product File No: 20160093

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of March 2021.

This approval is contingent upon compliance with the following stipulation(s):

1. The flowing water supply pressure at the point(s) of connection must be at least 25.9 psig.
2. The manufacture must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
3. This approval is for only the prefabricated plumbing system as defined herein. "Prefabricated Plumbing" means concealed drain piping, vent piping or water supply piping or a combination of these types of piping, contained in a modular building component, which will not be visible for inspection when delivered to the final site of installation.
4. There is no 3" main stack on the "A" units per Mfg.
5. **SPS 382.40(8)(g)**. Shower valves in public buildings shall be thermostatic mixing valves or pressure balanced mixing valves.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Timothy J. Lamb
Plumbing Plan Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
Madison WI 53703-2658
608-266-9647 Phone
608-267-9723 Fax
tim.lamb@wi.gov E-mail

Fee Required \$	250.00
Fee Received \$	250.00
Balance Due \$	0.00

WiSMART code: 7657