



June 24, 2014

DIAMOND WATER CONDITIONING
JOHN GRIESBACH / DAN SCHLENZ
N1022 QUALITY DRIVE
PO BOX 170
GREENVILLE WI 54942

Re: Description: WATER TREATMENT DEVICE - pH NEUTRALIZING
Manufacturer: DIAMOND WATER CONDITIONING
Product Name: LIBERATOR ACID NEUTRALIZERS
Model Number(s): AN-100A-LOGIX, AN-150A-LOGIX, AN-200A-LOGIX AND AN-250A-LOGIX
Product File No: 20140093

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of June 2019.

This approval is contingent upon compliance with the following stipulation(s):

- This product has undergone sufficient testing to document the product's ability to reduce only those contaminants and/or substances as specified in this approval letter when the product is installed and maintained in strict accordance with the manufacturer's published instructions.
- Where the Department of Natural Resources (DNR) has jurisdiction, a written approval may be required prior to installation of this product in a water supply system to reduce the concentration of a contaminant that exceeds the primary drinking water standards contained in ch. NR 809, Wis. Admin. Code, the enforcement standards contained in ch. NR 140, Wis. Admin. Code, or for a water supply system that is subject to a written advisory opinion by the DNR. For more information contact the DNR Section of Private Water Systems, P.O. Box 7921, Madison, WI 53707, telephone (608) 267-9787.
- If these approved devices are modified or additional assertions of function or performance are made, then this approval shall be considered null and void, unless the change is submitted to the department for review and the approval is reaffirmed.

Based on testing data submitted to and reviewed by the department, this approval recognizes that these plumbing products will reduce the concentration of contaminants as specified on pages 1 through 2 of this letter.

AESTHETIC CONTAMINANT REDUCTION CAPABILITIES
PRODUCT FILE NUMBER 20140093
TABLE 1 OF 1

Flow Rates: AN-100A-LOGIX = [3.0 gallons per minute (gpm) @ X 1.5 pounds per square inch – gauge (psig)]
AN-150A-LOGIX = 5.0 gpm @ 3.3 psig
AN-200A-LOGIX = 8.0 gpm @ 4.3 psig
AN-250A-LOGIX = 10.0 gpm @ 5.4 psig

Capacity: DCF6-100-100-AN = 500 gallons (gals.)
DCF6-150-100-AN = 750 gals.
DCF6-200-100-AN = 1,000 gals.
DCF6-250-100-AN = 1,250 gals.

Tested Contaminant	Average Influent Challenge (pH Units)	Average Effluent (pH Units)
pH (low)	4.0	6.5

Other Conditions: the contaminant reduction performance capabilities displayed for Table 1 of 1 were verified by testing conducted by TG Analytical Laboratory in general accordance with NSF Standard 42. The pH was artificially depressed using hydrochloric acid. To pass, the device must increase the influent challenge pH such that the effluent pH falls in a range of ≥ 6.5 to ≤ 8.5 .

These devices perform their pH function by slowly dissolving the sacrificial media they contain. This means the media component of these systems will have to be replaced on a regular basis. The frequency of media replenishment for a given device is a function of onsite water quality and water use patterns.

\leq = less than or equal to

\geq = greater than or equal to

This device was tested under controlled laboratory, or field, conditions. The actual performance of this device for a specific end use installation will vary from the tested conditions based on local factors such as water pressure, water temperature and water chemistry.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail