



July 3, 2014

WATER RIGHT INCORPORATED
KURT GRUETT
1900 PROSPECT COURT
APPLETON WI 54914

Re: Description: WATER TREATMENT DEVICE - SOFTENER/CATION EXCHANGE
Manufacturer: WATER RIGHT INCORPORATED
Product Name: ASP2 SERIES WATER CONDITIONERS (POE)
Model Number(s): ASP2-1044, ASP2-1054 AND ASP2-1354 (POE)
Product File No: 20140192

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of July 2019.

This approval supersedes the approval issued on July 30, 2009 under product file number 20090253.

This approval is contingent upon compliance with the following stipulation(s):

- This product has undergone sufficient testing to document the product's ability to reduce only those contaminants and/or substances as specified in this approval letter when the product is installed and maintained in strict accordance with the manufacturer's published instructions.
- Where the Department of Natural Resources (DNR) has jurisdiction, a written approval may be required prior to installation of this product in a water supply system to reduce the concentration of a contaminant that exceeds the primary drinking water standards contained in ch. NR 809, Wis. Admin. Code, the enforcement standards contained in ch. NR 140, Wis. Admin. Code, or for a water supply system that is subject to a written advisory opinion by the DNR. For more information contact the DNR Section of Private Water Systems, P.O. Box 7921, Madison, WI 53707, telephone (608) 267-9787.
- If these approved devices are modified or additional assertions of function or performance are made, then this approval shall be considered null and void, unless the change is submitted to the department for review and the approval is reaffirmed.
- These cation exchange water softeners shall be sized, installed, programmed and maintained such that wastewater volumes, total dissolved solids and chloride discharges are minimized.

Based on testing data submitted to and reviewed by the department, this approval recognizes that these plumbing products will reduce the concentration of contaminants as specified on pages 1 through 2 of this letter.

**WATER SOFTENING CAPABILITIES
 PRODUCT FILE NUMBER 20140192**

TABLE 1 OF 3

Model Numbers	Capacities*						Flow Rates vs. Pressure Losses
	Rating 1		Rating 2		Rating 3		
Sanitizer Plus ASP2 Series	Grains	Pounds	Grains	Pounds	Grains	Pounds	gpm @ psig
Metered							
ASP2-1044	7,300	3.2	11,400	9.3	11,800	12.4	9.0 @ 2.4
ASP2-1054	16,400	6.1	20,700	12.4	22,600	15.9	9.0 @ 2.8
ASP2-1354	28,300	9.5	33,600	15.9	36,900	21.2	9.0 @ 2.7

* The softener capacity rating is based on grains of hardness, due to calcium and magnesium cations, removed (as calcium carbonate) while producing soft water between successive regenerations and is related to the pounds of salt required for each regeneration. The tests run to generate the data for table 1 of 3 were conducted in accordance with column testing performed by Baumbach Labs.

**AESTHETIC TREATMENT CAPABILITIES
 PRODUCT FILE NUMBER 20140192**

TABLE 2 OF 3

Model Numbers	Combined Total Iron (Fe ⁺² + Fe ⁺³) and Manganese (Mn ⁺²)	
	Influent (mg/l ¹)	Effluent (mg/l ¹)
Sanitizer Plus ASP2 Series		
ASP2-1044	≤ 8.0	≤ 0.3
ASP2-1054	≤ 10.0	≤ 0.3
ASP2-1354	≤ 15.0	≤ 0.3

Other conditions: The tests run to generate the data for table 2 of 3 were conducted in accordance with column testing performed by Baumbach Labs. The total cumulative concentrations of hardness, total iron and manganese must be used to determine the proper sizing and programming of these products

¹ = milligrams per liter (mg/l) are equivalent to parts per million (ppm)
 ≤ = less than or equal to

* = unless otherwise indicated

**pH MODIFICATION CAPABILITIES
 PRODUCT FILE NUMBER 20140192**

TABLE 3 OF 3

Model Numbers	pH	
	Influent (pH Units)	Effluent (pH Units)
Sanitizer Plus ASP2 Series		
ASP2-1044	≥ 6.5	≤ 7.0
ASP2-1054	≥ 6.0	≤ 7.0
ASP2-1354	≥ 6.0	≤ 7.0

Other conditions: The tests run to generate the data for table 3 of 3 were conducted in accordance with column testing performed by Baumbach Labs.

≤ = less than or equal to

≥ = greater than or equal to

This device was tested under controlled laboratory, or field, conditions. The actual performance of this device for a specific end use installation will vary from the tested conditions based on local factors such as water pressure, water temperature and water chemistry. The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
 Environmental Engineer - Plumbing Product Reviewer
 Department of Safety and Professional Services
 Division of Industry Services
 Bureau of Technical Services
 (608) 267-1401 Phone
 (608) 267-9723 Fax
 glen.schlueter@wi.gov E-mail