



November 12, 2015

WATER QUALITY ASSOCIATION
MICHELLE ROGALNY
4151 NAPERVILLE ROAD
LISLE IL 60532

KINETICO INCORPORATED
WALTER VANCE
10845 KINSMAN RD.
NEWBURY OH 44065

Re: Description: WATER TREATMENT DEVICE - SOFTENER/CATION EXCHANGE
Manufacturer: KINETICO INCORPORATED
Product Name: PREMIER SERIES
Model Number(s): S150, S250, S250 OD, S350, S550, S650 AND S650 OD
Product File No: 20150234

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of November 2020.

This approval is contingent upon compliance with the following stipulation(s):

- This product has undergone sufficient testing to document the product's ability to reduce only those contaminants and/or substances as specified in this approval letter when the product is installed and maintained in strict accordance with the manufacturer's published instructions.
- Where the Department of Natural Resources (DNR) has jurisdiction, a written approval may be required prior to installation of this product in a water supply system to reduce the concentration of a contaminant that exceeds the primary drinking water standards contained in ch. NR 809, Wis. Admin. Code, the enforcement standards contained in ch. NR 140, Wis. Admin. Code, or for a water supply system that is subject to a written advisory opinion by the DNR. For more information contact the DNR Section of Private Water Systems, P.O. Box 7921, Madison, WI 53707, telephone (608) 267-9787.
- If these approved devices are modified or additional assertions of function or performance are made, then this approval shall be considered null and void, unless the change is submitted to the department for review and the approval is reaffirmed.
- These cation exchange water softeners shall be sized, installed, programmed and maintained such that wastewater volumes, total dissolved solids and chloride discharges are minimized.
- At the time of installation, these devices shall be provided with an effective means to warn the users when they are not performing their function. This shall be accomplished by one of the following:
 1. sounding and alarm or flashing a light, each connected to an acceptable power source;
 2. providing a sampling kit for analysis of hardness or other appropriate contaminants; or
 3. providing a hardness monitor.

**WATER SOFTENING CAPABILITIES
 PRODUCT FILE NUMBER 20150234
 TABLE 1 OF 1**

| Model Numbers | Capacity* | | | | Flow Rate @ Pressure Loss |
|----------------|-----------|--------|----------|--------|---------------------------|
| | Rating 1 | | Rating 2 | | |
| Premier Series | Grains | Pounds | Grains | Pounds | gpm @ psig |
| S150 | 6,728 | 1.5 | 9,783 | 3.0 | 9.0 @ 15.0 |
| S250 | 11,276 | 2.4 | 15,399 | 4.4 | 11.5 @ 15.0 |
| S250 OD | 11,276 | 2.4 | 15,399 | 4.4 | 23.0 @ 15.0 |
| S350 | 25,773 | 5.5 | 35,197 | 10.0 | 11.5 @ 15.0 |
| S550 | 50,371 | 12.5 | - | - | 12.7 @ 15.0 |
| S650 | 4,338 | 0.8 | 5,816 | 1.25 | 7.0 @ 15.0 |
| S650 OD | 4,338 | 0.8 | 5,816 | 1.25 | 11.0 @ 15.0 |

* The softener capacity rating is based on grains of hardness, due to calcium and magnesium cations, removed (as calcium carbonate) while producing soft water between successive regenerations and is related to the pounds of salt required for each regeneration. The tests run to generate the hardness reduction data for table 1 were conducted in accordance with NSF Standard 44.

This device is also approved for the reduction of barium up to a maximum influent concentration of 10 mg/l and radium up to a maximum concentration of 25 pCi/l. This device is also approved for the reduction of dissolved iron, up to a maximum concentration of 10 mg/l. Testing was conducted in accordance with ANSI/NSF Standard 44.

This device is efficiency rated (ER) at the lowest salt dosages displayed (i.e. "Rating 1").

- Operation of these devices at flow rates above the rated service flow rates specified within this approval letter are not supported or acknowledged by this approval. The rated service flow rates are the flow rates at which these devices were tested.

Because the level of treatment obtained is, in part, a function of how long the water is in contact with the treatment media within these devices, arbitrary increases in the flow rates above the rated service flow rates may compromise the quality of the treated water.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
 Environmental Engineer - Plumbing Product Reviewer
 Department of Safety and Professional Services
 Division of Industry Services
 Bureau of Technical Services
 (608) 267-1401 Phone
 (608) 267-9723 Fax
 glen.schlueter@wi.gov E-mail