SPS 316 ELECTRICAL CODE ADVISORY COMMITTEE MEETING TELECONFERENCE/VIRTUAL MEETING MINUTES September 26, 2016

- **PRESENT** Steven Bacalzo, Joseph Bembnister, Brad Gruenewald, Paul Gruettner, David Helgeson, Gene Jacobson (*arrived at 9:09 a.m.*,) Charles Johansen, Bill Neitzel, John Nikolai, James Rugg
- **EXCUSED** Shannon Clark
- **STAFF** Dale Kleven, Rules Coordinator; Anthony Tadysak, DIS Engineering Consultant; Nifty Lynn Dio, Bureau Assistant; and other Department staff

CALL TO ORDER

Bill Neitzel, called the meeting to order at 9:02 a.m. A quorum of nine (9) members was confirmed.

ADOPTION OF AGENDA

MOTION: Steven Bacalzo moved, seconded by Paul Gruettner, to adopt the agenda as published. Motion carried unanimously.

APPROVAL OF MINUTES

Amendments to the Minutes

- Page 2: Correct spelling of *interrupters*
- **MOTION:** Charles Johansen moved, seconded by Brad Gruenewald, to approve the minutes of August 29, 2016 as amended. Motion carried unanimously.

(Gene Jacobson joined the meeting at 9:09 a.m.)

REVIEW AND DISCUSSION OF SPS 305 AND 316 DRAFT RULE LANGUAGE

- **MOTION:** Charles Johansen moved, seconded by Bembnister Bembnister, to strike "on or after April 1, 2014" from in the draft rule language. Motion carried unanimously.
- **MOTION:** David Helgeson moved, seconded by Paul Gruettner, to revise SPS 316.012 (2)(e)2 in the draft rule language to state "The name and license number of the master electrician, residential master electrician, or the registered master electrician under SPS 305.437 responsible for the installation, unless exempted under s. 101.862(4), Stats." Motion carried. *Bembnister voted no.*

- **MOTION:** Gene Jacobson moved, seconded by John Nikolai, to accept DSPS staff recommended changes to the following sections of the draft rule language:
 - 1. SPS 316.020: Include the language that installations conform to the 2017 Natioanl Electrical Code incorporated by reference in this chapter.
 - SPS 316.210 (5): The language in existing SPS 316.210 (5) is identical to the language in 2017 NEC 210.70 (A) (1). SPS 316.210 (5) should be repealed.
 - 3. SPS 316.225 (2): NEC 225.30 (f) is not in the 2017 NEC (the change did not receive final approval). SPS 316.225 (20 should remain unchanged from how it currently reads.
 - 4. SPS 316.312 (2) and (3): Exception paragraphs are exception numbers in the 2017 NEC. The references to the exception paragraphs (b) and (c) should be changes to the exception numbers 2 and 3.
 - 5. SPS 316.675: The reference to NEC 230 subchapter VI should be changed to NEC 230 part VI.
 - 6. SPS 316.511 (1) and (2): Replace the language in the fourth line under "Extent of Classified Location" of Table 511.3(C). Since this is not an exception, the first sentence shouldremove the words "the exception under" an it would read "(1) Substitute the following wording for 'Extent of classified location...'." In addition, replace the language in the second line under "Extent of Classified Location" of Table 511.3(D). Same language change as above.

Motion carried unanimously.

- **MOTION:** Steven Bacalzo moved, seconded by Brad Gruenewald, to approve the draft language for SPS 305 and 316 as modified at today's meeting. Motion carried unanimously.
- **MOTION:** Paul Gruettner moved, seconded by John Nikolai, we as a committee refer our recommendations to DSPS as written and modified. Motion carried. Opposed: Johansen

ADJOURNMENT

MOTION: Steven Bacalzo moved, seconded by Charles Johansen, to adjourn the meeting. Motion carried unanimously.

The meeting adjourned at 11:36 a.m.

Electrical Code Advisory Committee Meeting Minutes September 26, 2016 Page 2 of 2